

# Project report: System ssący - serwerownia C GPD



## System provider:

Company:  
Address:  
Town:  
Phone:

## Customer:

Szczeciński Park Naukowo – Technologiczny Sp. z o.o.  
ul. Niemierzyńska 17a  
71-441 Szczecin

## Comment:


Budowa i wyposażenie I etapu POMERANIA TECHNOPARK w Szczecinie przy ul. Niemierzyńskiej

EN 54-20 class	EN 54-20 compliant	possible reasons
C	Yes	
B	Yes	
A	Yes	

Project name:	System ssący - serwerownia C GPD
Project build date:	2013-09-06 14:54:00
Fan level:	III
Ambient temperature [°C]	20
Ambient pressure [hPa]	950

	Tube network I	Tube network II
Maximum smoke sensor sensitivity according EN 54-20 class C	3.335	--
Maximum smoke sensor sensitivity according EN 54-20 class B	0.580	--
Maximum smoke sensor sensitivity according EN 54-20 class A	0.198	--
Maximum transport time [s]	27	--
Overall sampling tube length [m]	8.20	--
Number of sampling points	2	--

Sketch of tube network:



s:\Dokumenty\Odbiorcy\SPNT\DOKUMENTACJA AKTUALNA\SPNT SSAÇY\Serwerownia\_C\_GPD.report.gif

Part	Description	RL	TL	S[C]	S[B]	S[A]	P	FI	ø	t	L-cap	Comment:
	(ASD) ASD 535		0.00					0.14		0		
A1	(TU 25 PVC) Sampling tube D=25 mm PVC, l=5 m	1.80	1.80				259	0.14		0		
A2	(BE 25 PVC) Bend 90° D=25 mm PVC		1.80									
A3	(TU 25 PVC) Sampling tube D=25 mm PVC, l=5 m	0.40	2.20									
A4	(BE 25 PVC) Bend 90° D=25 mm PVC		2.20									
A5	(TU 25 PVC) Sampling tube D=25 mm PVC, l=5 m	2.60	4.80									
A6	(BE 25 PVC) Bend 90° D=25 mm PVC		4.80									
A7	(TU 25 PVC) Sampling tube D=25 mm PVC, l=5 m	1.40	6.20									
A8	(BE 25 PVC) Bend 90° D=25 mm PVC		6.20									
A9	(TU 25 PVC) Sampling tube D=25 mm PVC, l=5 m	2.00	8.20									
A9 - 1	-1- Sampling point / clip	0.50	6.70	6.670	1.160	0.400	258	0.07	2.00	20		
A9 - 2	-2- Sampling point / clip	1.30	8.00	6.670	1.160	0.400	258	0.07	2.50	27		
RL: Relative length of this part (distance to previous SP or bend) [m] TL: Total length of the part end to the ASD [m] S[C]: smoke sensitivity [%/m] for this sampling hole, when the smoke sensor alarm level is chosen as proposed in this report. S[B]: smoke sensitivity [%/m] for this sampling hole, when the smoke sensor alarm level is chosen as proposed in this report. S[A]: smoke sensitivity [%/m] for this sampling hole, when the smoke sensor alarm level is chosen as proposed in this report. P: Pressure [Pa] FI: airflow [Liter/s] of this sampling point t: transport time to the ASD [s] L-cap: Length of the capillary / stub [m]												

**Material list:**

<b>Part</b>	<b>Number</b>	<b>Length [m]</b>	<b>Rod length [m]</b>	<b>Number of rods</b>	<b>Comment:</b>
(ASD) ASD 535	1				
(TU 25 PVC) Sampling tube D=25 mm PVC, l=5 m	5	8.20			
(SO 25 PVC) Socket D=25 mm PVC	3				
(BE 25 PVC) Bend 90° D=25 mm PVC	4				
(EC 25 PVC) End cap D=25 mm PVC	1				
(CLIP 2.0 PA) Sampling hole clip d=2.0 mm red PA	1				
(CLIP 2.5 PA) Sampling hole clip d=2.5 mm red PA	1				
(PC 25 PP) Pipe clamp type Goema halogen-free	9				